



**Business Services
Contracts Office**

*John Quinto, Chief Business Officer
Jessica Sulli, Contract Specialist*

ADDENDUM NO. 1

Date: May 20, 2019

Issued by: Sacramento City Unified School District

Project: 0108-418, Ethel I. Baker Asphalt Replacement

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over the original documents. This Addendum shall be a part of the contract documents and shall take precedence over the original documents. This Addendum shall be a part of the contract documents and shall take precedence over the original documents.

Bid No. 0108-418, Ethel I. Baker Asphalt Replacement
Requests for Information

#	Bidder Name	Date Asked	Question	Response
1	McGuire & Hester	5/14/2019	Demolition plan, Sheet C1.1 shows a note No.12 but there is no description. Please clarify.	See addendum sheet C1.1. Note 12 to read "Remove volleyball post and footing".
2	McGuire & Hester	5/14/2019	In Section 321200 Asphalt Concrete Paving, paragraph 2.01.E calls for the AC aggregate at Playcourt to be 3/8 maximum grading. Is this correct?	Yes, the hardcourt aggregate shall be 3/8"
3	McGuire & Hester	5/14/2019	Also in Section 321200 Asphalt Paving, paragraph 3.03.C.1 calls for the Seal Coat to be applied no sooner than 30 days after AC placement. This will put this operation potentially past the time of completion of 60 calendar days and therefore the contractor in a position to pay liquidated damages. Please reconsider this requirement.	The sealcoat will be deleted from the contract.
4	McGuire & Hester	5/14/2019	Construction note 8 on sheet C3.1 indicates to provide a new threshold in concrete at the 5 classroom doors on the north side of the building. Do we need to pour 5 new concrete landings at those locations? Please clarify.	Only enough concrete to install a new threshold is required.

