



Business Services  
Contracts Office  
5735 47th Avenue • Sacramento, CA 95824  
(916) 643-2464

---

### **ADDENDUM NO. 1**

Date: October 26, 2017

Issued by: Sacramento City Unified School District

**Project: Outdoor Learning Center at John Sloat Elementary School**

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

---

#### **1. DRAWINGS – L-3**

a. Install new Hunter 12 station controller between the two portable buildings adjacent to project. Mount controller to wall. Contractor to run new 120v circuit in rigid conduit from panel on back of portable and connect power to controller. All fittings shall be rated for exterior applications.

#### **2. DRAWINGS – L-4, Detail A**

a. Change DG section to 3½ inches over compacted soil. DG installed in two lifts. Remove 6-inch section of road base.

**END OF ADDENDUM NO. 1**